

	<p style="text-align: center;">CLARENDON COUNTY PROCUREMENT</p> <p style="text-align: center;">REQUEST FOR QUOTE ADDENDUM #2</p>	<p>Solicitation Number</p>	<p>2024-Q001 - STORM DRAIN IMPROVEMENTS IN LAKE MARION SHORES</p> <p>Jeffrey Hyde, CPPB, NIGP-CPP Procurement Director project@clarendoncountygov.org</p>
---	--	--------------------------------	--

September 11, 2024 **Please remember to acknowledge all addendums

**NOTE: OUR NEW PROCUREMENT OFFICE LOCATION – 3 SOUTH CHURCH STREET
VOTER REGISTRATION and ELECTIONS BUILDING**

ADDENDUM #2 -The purpose of this **ADDENDUM** is to answer the question received by the deadline.

QUESTION/ ANSWER

1. **Q:** We need to know if the invert of the pipe is at 14.00 and the lake elevation is at 14.59, can we raise the invert and adjust the slope to meet final grade at the yard inlet?
A: **Invert of pipe at sea wall is 74.0. Have to maintain 12” of cover. Lake level varies.**

All other terms and conditions remain unchanged.

DEADLINE TO SUBMIT PROPOSALS: REMAINS UNCHANGED

SUBMIT TO: Jeffrey A Hyde, CPPB, NIGP-CPP
Procurement Director,
Clarendon County
3 South Church Street
Manning, SC 29102
Phone (803) 433-3240