

	CLARENDON COUNTY PROCUREMENT REQUEST FOR QUOTE ADDENDUM #2	Solicitation Number	2024-Q004: TARGET SITE PREPARATION FOR SHERIFF'S DEPT. FIRING RANGE Jeffrey Hyde, CPPB, NIGP-CPP Procurement Director jhyde@clarendoncountvgov.org
---	---	------------------------	--

December 02, 2024

**Please remember to acknowledge all addendums

**NOTE: OUR NEW PROCUREMENT OFFICE LOCATION – 3 SOUTH CHURCH STREET
VOTER REGISTRATION and ELECTIONS BUILDING**

ADDENDUM #2 -The purpose of this **ADDENDUM** is to address the questions received by 11/27/2024.

QUESTION/ANSWER

1. **Q:** Will RCP-2 receptacles for be located near the air compressor inside the building or at the firing line?
A: Inside for dryer and auto drain plus two (2) at firing line.

2. **Q:** Will any receptacles be needed at the firing line?
A: Yes, two (2) per Action Target sheet Z701 and County site plan

3. **Q:** Will PVC be approved for use above grade for power?
A: Yes - where permitted under National Electrical Code.

4. **Q:** Who is responsible for ethernet conduit/wire from service to building? If Electrical Contractor is for either, where/how far is connection point for service from the building?
A: County to provide internet service to building for equipment.

All other terms and conditions remain unchanged.

DEADLINE TO SUBMIT PROPOSALS: REMAINS UNCHANGED

SUBMIT TO: Jeffrey A Hyde, CPPB, NIGP-CPP
Procurement Director, Clarendon County
3 South Church Street
Manning, SC 29102
Phone (803) 433-3240