



# Fire Sprinkler System Specification Sheet

(Per §40-10-250)



Project Data				
Project name: Turbeville Branch Library				
Location in South Carolina:	Address (street # & name): 1178 Smith Street		State Project: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	City: Turbeville	County: Clarendon	State Project #:	
Water Supply Information				
(Flow test data must be less than 1 year old per §40-10-250(A)(1))				
Date test conducted: / /	Static pressure (psi): TBD	Residual pressure (psi): TBD	Flow (gpm): TBD	
Distances of test gauges relative to the base of the riser:		Horizontal (ft): 300	Vertical (elevation difference in ft): 0	
Source of water supply:	<input type="checkbox"/> Municipal dead-end <input checked="" type="checkbox"/> Municipal circulation <input type="checkbox"/> existing fire pump <input type="checkbox"/> Other:			Pipe Size (in.): 6
Test data by/from:	Name: Ellis Evans		Title:	
	Organization: Turbeville Water Department		Phone: 843-373-9273	
Fire pump:	<input type="checkbox"/> New <input type="checkbox"/> Existing	Rated Pressure (psi):	Churn Pressure (psi):	
	<input checked="" type="checkbox"/> No Pump	Rated Capacity (gpm):	Pressure @ 150% flow (psi):	
On-site water storage:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> New <input type="checkbox"/> Existing <input type="checkbox"/> Tank <input type="checkbox"/> Other:	Capacity (gal):	
NFPA Hazard Classification				
(Attach continuation page when necessary)				
Area #	Hazard Class or Code Reference	Description of Hazard Protected (including occupancy use group, and details of storage arrangement as applicable (including commodity class, rack arrangement/type, ceiling and storage height.))		
1	Light Hazard	Office, Workroom, Kitchen, Restrooms, Lobby, Meeting Room		
2	Ordinary Hazard, Group 1	Electrical Rooms, Storage Rooms		
3	Ordinary Hazard, Group 1	Attic Spaces		
Design Parameters				
(Attach continuation page when necessary)				
Area #	System Type	Density(gpm/ft <sup>2</sup> )/Area(ft <sup>2</sup> ), or Other	Inside Hose (gpm)	Outside Hose (gpm)
1	Wet	0.10 gpm/sf/1500 sf *	0	100
2	Wet	0.15 gpm/sf/1500 sf *	0	250
3	Wet	0.15 gpm/sf/1950 sf	0	250
Seismic Design Data: S <sub>s</sub> = 0.55g		Site Classification= D	Seismic Design Category= D	
Codes and Standards				
(Attach continuation page when necessary)				
Applicable Codes, Standards, & Editions (i.e. 2018 IBC, 2016 NFPA 13, etc.) for the Scope of Work on the Fire Sprinkler System				
Wet Pipe Sprinkler System: NFPA-13 (2019), IBC (2021), IFC (2021)				
* Area reduction per 19.3.3.2.3.2 is allowed				
Scope of work (i.e. sprinkler system A.G. from 1'-0" A.F.F., U.G. from tap to 5'-0" outside, etc.) and notes (attach continuation page when necessary):				
• Fire sprinkler contractor's work begins 1'-0" above finished floor at the riser.				
Specifier's Information				
Name: Samuel C. Stephens, P.E.		<div style="display: flex; justify-content: space-around;"> </div>		
Engineering services provided through a firm: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Firm name: Stephens Engineering & Consulting, LLC				
Address: 130 Heritage Lane				
City: Easley				
State: SC	Zip: 29642			
Phone: 864-414-1965	Fax:			
E-mail: sam@stephensec.com				

Revision No.: 0

Page 1 of 1

Signature:   
Date: 6-5-2025